

# Reactive Power Compensation for Solar Power Plants

**Andy Leon**

**IEEE PES Chicago Chapter**

**December 12<sup>th</sup>, 2018**

# Objectives

- Refresh the basics of reactive power from a generator's perspective
- Regulatory history and recent changes
- Differences between wind/solar
- Inverter quantity and plant specifications
- How to get involved

# Developer's Perspective

- Preliminary engineering in house – cost estimates and lead times very important
- Detailed engineering and studies carried out by consultants
- Obligated to demonstrate reactive power compliance and pass tests to remain in compliance

# IEEE PES Resource Center



IEEE PES  
**RESOURCE**  
CENTER

IEEE Power & Energy Society

Conference Videos & Slides ▾ Technical Publications ▾ Education ▾ | INDEX Join PES

## Wind Power Plant Collector Design

IEEE Power & Energy Society  
Aug 2016

TECHNICAL PAPER COMPENDIUM  
PES-TPC3

Posted: 4 Aug 2016

Primary Committee:

Energy Development and Power Generation Committee


Sponsored by:

Integration of Renewable Energy into the Transmission and Distribution Grids Subcommittee



### Wind Power Plant Collector Design

PREPARED BY THE  
Energy Development and Power Generation Committee  
Integration of Renewable Energy into the Transmission  
and Distribution Grids Subcommittee  
Wind and Solar Plant Collector Design Working Group



# IEEE Wind and Solar Plant Collector Design Working Group

▶ Table of

## Scope:

- Serve as a focal point within the Power & Energy Society (PES) for addressing issues related to the design of collector systems for wind plants, including tradeoffs associated with overhead vs. underground lines, grounding, distribution equipment applications, cost and reliability tradeoffs for the unique characteristics of this energy resource, protection, reactive compensation, and SCADA application.
- Conduct activities to promote the sharing of knowledge and experience among diverse organizations working on similar issues through the conduct of studies, symposia, workshops, paper session, panel sessions, and tutorials.
- Publish working group papers to document results of working group activities and to share working group positions on issues related to the design of collector systems for wind plants.

## Working Group Officers:

### Chair:

Loren Powers

DNV GL

E-mail: [Loren.Powers@dnvgl.com](mailto:Loren.Powers@dnvgl.com)

### Vice Chair:

Sudipta Dutta

GE Energy Consulting

E-mail: [Sudipta.Dutta@ge.com](mailto:Sudipta.Dutta@ge.com)

### Secretary:

Rob Schaerer


POWER Engineers, Inc

E-mail: [Rob.Schaerer@powereng.com](mailto:Rob.Schaerer@powereng.com)


- WG meeting Tuesday January 15<sup>th</sup>, 8am-12pm at IEEE JTCM in Anaheim
- 2019 IEEE PES GM in Atlanta August 4<sup>th</sup>-8<sup>th</sup>
  - WG sponsoring a 2 hour PV Solar Power Plant Design panel session
  - WG and grounding task force scheduled to meet

# Reactive Power

- Inductive/capacitive loads on the grid shift the phase angle between voltage and current
- Generators can control their power factor



# Reactive Power



- 100MW
- Unity power factor: 100MVA, 100MW, 0MVAR
- 0.95 power factor: 105MVA, 100MW, 33MVAR
- 0.90 power factor: 111MVA, 100MW, 48MVAR
- Higher MVA = higher current, higher losses


# Regulatory Timeline

- 2003: FERC issues standard interconnection agreement and procedure for large generators
- 2005: FERC 661 requires a wind power factor range of  $\pm 0.95$  *if required by studies*.
- 2016: FERC 827 requires all large non-synchronous generators to maintain a *dynamic*  $\pm 0.95$  at the high side of the project substation, at all generation levels.


# Voltage Controller

- Wind farm management system packaged with turbines, solar farm management systems often third party integrated
- Can operate in voltage mode, var mode, power factor mode
- Voltage mode most common – SFMS monitors grid voltage and dispatches reactive power to maintain voltage setpoint at POI


## MPT HIGH SIDE VOLTAGE COMPARISON




## REACTIVE POWER AT HIGH SIDE OF MPT COMPARISON




# Regional Variance




# Voltage Schedule



# Voltage Schedule



# Inverter P/Q Curves



# Inverter P/Q Curves

- Request P/Q Curves and documentation from manufacturer to cover:
  - Real/reactive power standard limitations
  - Ambient temperature derating
  - DC voltage limits on apparent power or reactive power
  - AC terminal voltage derating
  - Priority modes – defaults and what is configurable

# Quantity of Solar Inverters

- FERC 827 requires 0.95 dynamic power factor
- 100MW solar project example
  - 2.5MVA inverters (inverters rated with MVA)
  - 42 inverters?  $100\text{MW}/105\text{MVA}=0.952 \text{ pf}$
  - 43 inverters?  $100\text{MW}/107.5\text{MVA}=0.93 \text{ pf}$
- Consider derating factors

# Inverter Temperature Limits

- Ambient temperature de-rating
  - Maximum site design temperature?
  - Maximum possible site temperature?
  - Reactive compliance at high temperatures? Q vs P priority?

# Inverter AC Voltage Limits

- 0.9pu – 1.1pu voltage common continuous operating limit.
- Thermal MVA rating at low AC terminal voltages. Q priority?
- Reactive power limitations based on grid voltage. Can be countered with on load tap changer or deenergized tap optimization.

# Inverter DC Voltage Limits

- Injection of AC current onto grid requires DC voltage to exceed AC RMS peak voltage
- Inverter Maximum Power Point Tracking typically selects a DC voltage that optimizes real power output.
- Injection of capacitive lagging reactive power onto grid can be problematic, especially with lower DC rated inverters. Q prioritized.

# Modeling for Studies

Machine Data Record

Power Flow Short Circuit

Basic Data

Bus Number 15002 Bus Name 002 0.6900

Machine ID 1 ☒ In Service Bus Type Code 2

Machine Data

Pgen (MW) 2.5000 Pmax (MW) 2.5000 Pmin (MW) 0.0000

Qgen (Mvar) 0.0000 Qmax (Mvar) 1.6 Qmin (Mvar) -1.6

Mbase (MVA) 2.78 R Source (pu) 0.000000 X Source (pu) 0.200000

Transformer Data

R Tran (pu) 0.00000 X Tran (pu) 0.00000

Gentap (pu) 1.00000

Owner Data

| Owner                                       | Fraction |
|---------------------------------------------|----------|
| 1 <input type="button" value="Select ..."/> | 1.000    |
| 0 <input type="button" value="Select ..."/> | 1.000    |
| 0 <input type="button" value="Select ..."/> | 1.000    |
| 0 <input type="button" value="Select ..."/> | 1.000    |

Wind Data

Control Mode 0 - Not a wind machine

Power Factor (WPF) 1.000

Plant Data

Sched Voltage 1.0000 Remote Bus 0

OK Cancel

# Load Flow Results

| Case # | POI Voltage (p.u.) | Description | Reactive test | HS DETC Tap Ratio | Pad mount Tap Ratio | Shunts (T1) MVAR | P (MW) | Q (MVAR) | Q required |
|--------|--------------------|-------------|---------------|-------------------|---------------------|------------------|--------|----------|------------|
| 1      | 1.0000             | 100% Gen    | VAR           | 1.00000           | 1.025               | 0.000            | 24.55  | -4.34    | N/A        |
| 2      | 1.0000             | 100% Gen    | Lag           | 1.00000           | 1.025               | 0.000            | 24.52  | 8.22     | 8.2170     |
| 3      | 1.0000             | 100% Gen    | Lead          | 1.00000           | 1.025               | 0.000            | 24.52  | -8.22    | -8.2170    |
| 4      | 1.0500             | 100% Gen    | Lag           | 1.00000           | 1.025               | 0.000            | 24.57  | 4.11     | 4.1085     |
| 5      | 1.0500             | 100% Gen    | Lead          | 1.00000           | 1.025               | 0.000            | 24.55  | -8.22    | -8.2170    |
| 6      | 1.0300             | 100% Gen    | Lag           | 1.00000           | 1.025               | 0.000            | 24.54  | 8.22     | 8.2170     |
| 7      | 1.0300             | 100% Gen    | Lead          | 1.00000           | 1.025               | 0.000            | 24.54  | -8.22    | -8.2170    |
| 8      | 0.9700             | 100% Gen    | Lag           | 1.00000           | 1.025               | 0.000            | 24.50  | 8.22     | 8.2170     |
| 9      | 0.9700             | 100% Gen    | Lead          | 1.00000           | 1.025               | 0.000            | 24.50  | -8.22    | -8.2170    |

# Load Flow Results

| Case # | POI Voltage (p.u.) | Description | Reactive test | Inverter Terminal Voltage (p.u.) |       |       | 34.5 kV Collector Voltage (p.u.) |       |       |
|--------|--------------------|-------------|---------------|----------------------------------|-------|-------|----------------------------------|-------|-------|
|        |                    |             |               | Max                              | Avg.  | Min   | Max                              | Avg.  | Min   |
| 1      | 1.0000             | 100% Gen    | VAR           | 0.975                            | 0.973 | 0.972 | 0.994                            | 0.992 | 0.991 |
| 2      | 1.0000             | 100% Gen    | Lag           | 1.057                            | 1.057 | 1.057 | 1.049                            | 1.047 | 1.046 |
| 3      | 1.0000             | 100% Gen    | Lead          | 0.947                            | 0.947 | 0.947 | 0.977                            | 0.975 | 0.974 |
| 4      | 1.0500             | 100% Gen    | Lag           | 1.075                            | 1.075 | 1.075 | 1.079                            | 1.077 | 1.076 |
| 5      | 1.0500             | 100% Gen    | Lead          | 0.996                            | 0.996 | 0.996 | 1.027                            | 1.025 | 1.025 |
| 6      | 1.0300             | 100% Gen    | Lag           | 1.084                            | 1.084 | 1.084 | 1.078                            | 1.075 | 1.075 |
| 7      | 1.0300             | 100% Gen    | Lead          | 0.976                            | 0.976 | 0.976 | 1.007                            | 1.005 | 1.004 |
| 8      | 0.9700             | 100% Gen    | Lag           | 1.031                            | 1.031 | 1.031 | 1.021                            | 1.019 | 1.018 |
| 9      | 0.9700             | 100% Gen    | Lead          | 0.918                            | 0.918 | 0.918 | 0.946                            | 0.944 | 0.944 |

# Best practices

- Use reasonable or code required assumptions:
  - Power factor criteria and enforcement point
  - Ambient temperature – consider energy model
  - Any relevant DC voltage limitations?
  - Voltage schedule, which cases to run at extremes
  - Specify enough inverters for .95 dynamic capability at typical site maximum temperature
  - To compensate for losses, evaluate cap banks, reactors, or other reactive power compensation.

# Simulation vs. reality?

- Q priority, what happens with derating, how is plant controller programmed.
- On load tap changer movement.

# On load tap changers

| POI Voltage<br>(Voltage Set<br>point)<br>(p.u.) | Dispatch | Reactive Test | Real Power<br>Deliverable to<br>POI (MW) | Reactive Power<br>Deliverable to POI<br>(MVar) | Station Transformer<br>Tap Position | Total Switched<br>Shunts in Service<br>(+MVar cap.,<br>-MVar react.) | Lowest<br>Terminal<br>Voltage | Highest<br>Terminal<br>Voltage |
|-------------------------------------------------|----------|---------------|------------------------------------------|------------------------------------------------|-------------------------------------|----------------------------------------------------------------------|-------------------------------|--------------------------------|
| 1.009                                           | 100% Gen | Max Lagging   | 292.45                                   | 96.63                                          | 1.01875/1.02500                     | 0.0/0.0                                                              | 1.074                         | 1.095                          |
|                                                 |          | Max Leading   | 291.80                                   | -96.67                                         | 1.01875/1.02500                     | 0.0/0.0                                                              | 0.949                         | 0.949                          |
|                                                 | 10% Gen  | Max Leading   | 28.96                                    | 97.50                                          | 1.00625/1.00625                     | 0.0/0.0                                                              | 1.063                         | 1.063                          |
|                                                 |          | Max Leading   | 28.42                                    | -97.45                                         | 1.00625/1.00625                     | 0.0/0.0                                                              | 0.917                         | 0.917                          |
| 1.038                                           | 100% Gen | Max Lagging   | 292.48                                   | 96.75                                          | 1.05000/1.05625                     | 0.0/0.0                                                              | 1.072                         | 1.092                          |
|                                                 |          | Max Leading   | 291.78                                   | -97.20                                         | 1.05000/1.05625                     | 0.0/0.0                                                              | 0.946                         | 0.946                          |
|                                                 | 10% Gen  | Max Leading   | 28.99                                    | 96.69                                          | 1.03750/1.03750                     | 0.0/0.0                                                              | 1.059                         | 1.059                          |
|                                                 |          | Max Leading   | 28.42                                    | -96.64                                         | 1.03750/1.03750                     | 0.0/0.0                                                              | 0.915                         | 0.915                          |

# Q at night

- Most grid codes (and 827) do not require VAR support when there is no power generation.
- Possible concerns:
  - Utility disconnects plant if charging currents from cable/t-line are contributing to high voltages
  - Plant voltages exceed equipment ratings
  - Real power consumption if Q at night enabled (auxiliary and no load losses)

# Other considerations

- Shunt switching – flicker, voltage step %
- Harmonics
- Tap changer tradeoffs
- Actual test protocols

# Wind and Solar Power Coordinating Committee

Enroll on mailing list:

<https://s01.123signup.com/enroll?Org=IPWASPCC>

# Questions?

Andy Leon, [aleon@invenergyllc.com](mailto:aleon@invenergyllc.com)

